

Town of Baileyton W.W.T.P.

**6530 Horton Highway
Greeneville, TN 37745
Phone #(423) 234-6911
Fax # (423) 234-5442**



April 6, 2017



To; Sandra K. Vance

The Davy Crockett pump station experienced an overflow around 6:00 pm On April 5, 2017. The pump station overflowed about 200 gallons of raw sewage. The cause of the overflow was not the Town's fault but the Davy Crockett Truck Stop. Their sewer lines and tank were clogged before the Town's pump station. When Davy Crockett got their lines and tank unclogged it caused the pump station to overflow because of the backed up sewage overloaded the Town's pump station. Billy Sanders done the necessary cleanup and put down lime to disinfect where the station overflowed.

The Town of Baileyton is going to have a meeting and also send Davy Crockett Truck Stop a letter informing them that from now on when they are going to have a septic tank truck pump out and clean their sewage trash tank that they have to inform the town the day before it is to be pumped so we can have someone on site to make sure they are pumping out the grease and solids, not just the water. The Town of Baileyton hopes this will resolve this problem in the future.

If you have any further questions, please feel free to contact me at (423) 620-8208 or (423)-234-0991 at any time.

Danny P. Neely
Waste Water Operator

A handwritten signature in cursive script that reads "Danny P. Neely".